



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/06/2025

Shift: B

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11 Carriage drive	MPCB tripped	made ON	16:05:00	16:15:00	
2	OHP	WOBR on CO 26	BC not running	Wrong complaint	16:30:00	16:40:00	
3	OHP	CO 9	BRS kept in circuit	As per operation request . Again acting frequently , BRS bypassed .	19:00:00	20:00:00	BRS bypassed at CJB
4	OHP	TBS on CO 22	LT not taking place	LT drive OLR acted, reset done	18:30:00	18:45:00	
5	OHP	VS 2	OLR acted	reset done	19:00:00	19:10:00	
6	OHP	WOBR on CO 25	LT not taking place due to track jamming	Drive tripped , reset done. Also informed operation for track cleaning	20:15:00	20:30:00	
7	OHP	TT 2	Cable got cut	Temporary joint done and given clearance	20:00:00	21:00:00	
8	OHP	CO 3A	BRS not getting reset	Cable loose in TB , tightened	20:50:00	21:05:00	
9	CHP	CC 105 , SCR 10	BC signal missing	PLC recycled	14:45:00	15:20:00	
10	CHP	CC 32 , SCR 5	LT not working (8 times)	M-2 , M-3 and M-6 tripped. Reset done and informed to mechanical and operation	15:00:00	21:15:00	
11	CHP	CC 105 SCR 10 , CC 39 SCR 7	BC signal missing	LT done	20:10:00	20:30:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/06/2025

Incharge(s): Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	cc 131	Tripped on overload (3 times)	reset done	16:25:00	20:50:00	
13	CHP	CC 130	TIS motor tripped on over load due to heavy metal stucked	Removed metal , TIS reset done. Healthy and given clearance	19:15:00	19:25:00	