



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/08/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-87	Reported not healthy	OLR acted.Reset done	17:40:00	18:00:00	
2	OHP	TT4	Reported no power	Checked and found cable got opened at a joint.Temporary joint done and placement given and power kept off for permanent joint.	14:00:00	14:45:00	Permanent joint done and power made on
3	OHP	TBS on CO-23	Reported LT not taking place	M4 overload acted.Reset done	20:40:00	21:00:00	
4	OHP	BRC on CO-31	Reported no power	ACB tripped.MADE on	17:30:00	17:40:00	
5	CHP	CC-111 SCR-8	Reported reclaiming signal not coming	Bypassed in program and later program modified by general shift and tested okay.bypass removed	18:45:00	19:45:00	
6	CHP	CC-32 SCR-5	Reported B/C not running and LT not taking place	B/C OLR acted and LT drive tripped.B/C and LT reset done and tested okay	19:50:00	20:00:00	
7	CHP	CC-44	Reported not healthy	OLR acted.Reset done(2times)	21:25:00 21:28:00	21:28:00 21:30:00	
8	CHP	CC-15	Reported not healthy	SPP acted in MPD.reset done	17:15:00 18:15:00	17:30:00 18:30:00	
9	CHP	CC-51	Reported not healthy	OLR acted.Reset done(2times)	20:30:00	20:40:00	
10	WT	OC-1A(B/D)	Reported not healthy	OLR acted.Reset done	21:05:00	21:15:00	