



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/10/2025

Area: OHP

Equipment	Job
brc-5 on co-8a	bridge conveyor motor failed, motor changed with spare one and tested .
lc4,lc3,om-24 and jh O-14	de watering is being done.
JH O-3 to O-4	bay lighting circuit checked and restored illumination,
tt-3 and tt-2 on co-22	proximity sensor is changed and restored in circuit.
co 76r,68	motor and feeder side ppm is done.