



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/06/2025

Area: IOSA

| Equipment         | Job   |
|-------------------|---|
| BLENDER RECLAIMER | ISOLATOR AND VACCUM INTERRUPTOR UNIT CABLE ISOLATION IS IN PROGRESS           |
| OC-19A            | TUNNEL LIGHTING DEFECTS RECTIFIED AND LIGHT ARRANGED.                         |
| OC-21A            | LIGHTING DEFECTS RECTIFIED AND RECTIFIED LIGHTS ARRANGED.                     |
| OC-37A            | PPM DONE ON MOTOR AND FIELD DEVICES. SPARE MOTOR CLEANING AND MEGGERING DONE. |