



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/10/2025

Area: WT

Equipment	Job
OP 9 and 10	phase indication lamps @ D S L rectified and replaced in OP 10
MIS	spare LOTUS modem removed and brought from OP 7
OP 9	panel and Motor side ppm done, top C clamp and one jumper replaced
OP 10	D1,D5, and D6, cable insulation provided near T B
OP 10	All drives de clutch and moved with single drive in clutch with all drives found OK
OP 10	PPM done both motor and panel side
OP 1 and 2	After rake maintenance done