



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/12/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	REPORTED B/W-2 NOT RUNNING CHECKED AND FOUND MULTI DISK DAMAGED	INFORMED TO MECHANICAL	06:50:00	07:10:00	
2	OHP	TBS ON CO-22	REPORTED LBC STOPPING ON ZSS FOUND ZSS CAGE STUCK UP WITH STONE	REMOVED THAN OK	07:50:00	08:05:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	13:10:00	13:20:00	
4	OHP	CO-111 B/D	TRIPPED ON OLR	RESET DONE	11:00:00	11:05:00	
5	OHP	RSCO-10A	STOPPING ON ZSS FOUND ZS PROBE FIXING CHECK NUT LOOSE	ZSS PROBE GAP ADJUSTED AND CHECK NUT TIGHT THAN OK	12:40:00	12:55:00	
6	OHP	CC-51	MPD TRIPPED FEEDING CONVEYOR STOP (16 TIMES)	RESET DONE	07:10:00	13:35:00	
7	CHP	CC-53	MPCB TRIPPED	MPCB MADE ON THAN OK	13:15:00	13:30:00	
8	CHP	CC-51	TRIPPED ON OLR (2TIMES)	RESET DONE	09:10:00	09:20:00	
9	CHP	CC-130	REPORTED NOT RUNNING CHECKED AND FOUND VFD DRIVE CONTROL WIRE LOOSE CONNECTION	RECTIFIED THAN OK	12:15:00	13:15:00	
10	CHP	CC-104 SCR-9	REPORTED SLEW NOT WORKING LIMIT ACTED DUE TO JAMMING INFORMED TO OPERATION	AFTER CLEAR THE MATERIAL LIMIT RELEASED THAN OK	07:30:00	07:50:00	
11	CHP	CC-125	TRIPPED ON OLR	RESET DONE	08:50:00	08:55:00	
12	IOSA	BRC	CT END LIMIT ACTED	RELEASED	07:00:00	07:10:00	