



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/12/2025

Area: OHP

Equipment	Job
co-61,64 belt and carriage;	motor and panel side ppm is done.
brc -2 on co-28	ppm is done ; lighting is improved.
brc-4 on co-8a	ct limit switch of chp side is welded in position ; chp side needs to be fixed and taken into circuit.
TIS-2	motor meggered along with cable trail run taken, current is balanced (4A) and restored in circuit after trail run is complete.