



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 02/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-6a	Reported B/C not running	BSS acted.Released and tested okay	14:30:00	14:40:00	
2	OHP	TBS on CO-20	LT not taking place	PCRD OT acted.Released and tested okay	17:00:00	17:15:00	
3	OHP	BF-2A,5A	Reported ZSS acting	Probe gap adjusted and tested okay	17:35:00	17:45:00	
4	CHP	CC-51	Reported tripped	OLR acted.Reset done(8 times)	15:30:00	21:40:00	
5	CHP	Cc-54	Reported tripped	OLR acted.Reset done(2 times)	17:40:00	17:50:00	
6	CHP	Cc-114	Reported tripped	OLR acted.	20:50:00	21:00:00	
7	CHP	Cc 125	Reported tripped	OLR acted.Reset done	17:35:00	17:40:00	
8	CHP	Cc 31 scr4	Reported slew and B/W not working	OIL level low.Informed to mechanical	18:50:00	21:10:00	
9	CHP	CC 37 SCR-7	Reported LT not working	PCRD OT acted.Released and tested okay	18:30:00	18:45:00	
10	CHP	CC 37 SCR-7	B/C not working	OLR acted.Reset done	20:50:00	21:10:00	
11	CHP	CC 37 SCR-7	Slew not working	Break fail alarm reset done.30 degree slew limit bypassed and tested okay	21:10:00	21:45:00	
12	CHP	CC 32 R-1	B/C not running	ZSS cage stuck.Made free and tested okay	21:45:00	22:00:00	
13	WT	OT-5	Reported tripped	Drive 1 tripped.Reset done	19:45:00	19:50:00	
14	WT	OT-5	Reported tripped	Drive-2 tripped.Reset done	19:55:00	20:10:00	
15	WT	OT-3	Reported not rotating	Checked and found brake diodes failed.diodes changed.control problem rectified and C-2 in drive panel bypassed as coil burnt.	20:00:00	21:00:00	