



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/11/2025

Area: CHP

Equipment	Job
CC-222,223 Belt scales	ppm work done
Misc	All yard machines MCC rooms lighting rectification done and sufficient lighting provided
Misc	All yard machines PCRD inspection work done
CC-39,SCR-2	cabin focus lamp is replaced
CC-108	BRS checked and found sensor misalignment. Rectified and kept in circuit
CC-43,CC-107	ppm work done
RG lighting	Ground floor 400w HPSV light fittings cleaning done and 2no's lighting circuit rectification done, lighting cable laid and proper dressing done
RG lighting	Ground floor 250w light fitting circuit rectification done