



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11(C/D)	MPCB tripped	Made on(2 times).	19:00:00	19:15:00	Due to track jamming
2	OHP	CO-33M	Reported tripped	OLR acted.Reset done(2 times)	16:40:00	18:25:00	
3	OHP	CO-25	Reported tripped	OLR acted.Reset done(3times)	16:50:00	20:40:00	
4	OHP	BPC-1	Reported ZSS acting	Probe replaced and tested okay	20:30:00	20:50:00	
5	OHP	CO-26	Reported tripped	OLR acted.Reset done	15:50:00	16:00:00	
6	OHP	CO-111	Reported tripped	OLR acted.Reset done(2times)	15:00:00	15:25:00	
7	OHP	CR-1A	Pump reported not running	Low oil level	18:30:00	18:40:00	Informed to operation
8	OHP	BRC on CO-31	BW-1 not running	Electrically okay	18:30:00	18:40:00	Informed to mechanical
9	OHP	CO-21	ZSS acting	Probe replaced and tested okay	20:30:00	20:50:00	
10	CHP	CC-108	Chute sensor acted	Module problem.Replaced and tested okay	15:20:00	15:40:00	
11	CHP	Cc-33 R-1	B/C not running	Interlock ZSS cage stuck.Made free and tested okay	21:45:00	22:00:00	
12	CHP	Cc-54	Reported tripped	OLR acted.Reset done(14 times)	15:00:00	21:30:00	
13	CHP	Cc-51 MPD	Reported tripped	OLR acted.Reset done	15:00:00	16:30:00	
14	CHP	CC `131	Reported tripped	OLR acted.Reset done	15:20:00	15:30:00	
15	CHP	CC 131	BSS acting	Due to off centering.	16:00:00	16:10:00	Informed to operation
16	WT	OT-3	Reported tripped	D-1 tripped on encoder fault.Reset done	16:40:00	16:45:00	