



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-13(C/D)	Reported tripped	OLR acted.Reset done	15:25:00	15:30:00	
2	OHP	BRC on CO-32	CT not moving	Wrong complaint	16:15:00	16:30:00	
3	OHP	CO-85	Reported tripped	OLR acted.Reset done	17:10:00	17:15:00	
4	OHP	CO-15	Reported tripped	OLR acted.Reset done	19:20:00	19:25:00	
5	OHP	CO-58 (B/D)	Reported tripped	OLR acted.Reset done	19:25:00	19:30:00	
6	OHP	CO-26	Reported tripped	OLR acted.Reset done	19:55:00 20:55:00	20:00:00 21:00:00	
7	OHP	CO-29	Reported tripped	OLR acted.Reset done	21:35:00	21:40:00	
8	OHP	BRC on CO-30	B/W-2 not running	MCCB tripped.Winding cable touched with body.TB removed and power and winding cable direct joint done.	16:30:00	17:40:00	
9	OHP	BRC on CO-32	B/c not running	CJD acted due to chute jamming.	21:22:00	21:30:00	Informed to operation
10	OHP	BRC on CO-33M	B/C not working	OLR acted.Reset done	21:50:00	21:55:00	
11	CHP	Cc-28	TT CJD	Cable problem rectified and kept in line	14:30:00	14:50:00	NO delay
12	CHP	Cc-28	Reported tripped	OLR acted.Reset done	19:00:00	19:10:00	
13	CHP	CC-103 on Cc-105	Indication missing	I/O rack side wire loose.Properly connected and tested okay	14:30:00	14:45:00	
14	CHP	Cc-31 SCR-4	LT not taking place	Checked and found okay	14:35:00	14:45:00	Wrong complaint



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	Cc-35 SCR-3	Reported Lt not taking place	Drive tripped on OLR.Reset done	15:50:00	16:00:00	
16	CHP	CC-104 SCR-9	Slew not taking place.	Slew pump MPR tripped.Reset done and tested okay	19:40:00	19:55:00	
17	CHP	Cc-51	Reported tripped.	MPD tripped(15 times).Reset done	15:30:00	21:40:00	
18	CHP	Cc-54	Reported tripped	OLR acted.Reset done	21:10:00	21:15:00	
19	WT	EOT (ore side)	Reported no power	MCCB tripped at OT-3 area.Made on	15:30:00	15:45:00	
20	WT	OT-1	Reported not moving	Drive-1 tripped on PGEF fault.Reset done	19:10:00	19:15:00	
21	WT	AF-3	Reported Tripped	OLR acted.Reset done	20:00:00	20:05:00	