



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 12A	OLR ACTED	RESET	01:25:00	01:30:00	
2	OHP	BRC ON CO 30 LT	BREAK MPCB OFF	MADE IT ON	00:15:00	00:30:00	
3	OHP	BRC ON CO 28	B/C OLR ACTED	RESET	01:15:00	01:30:00	
4	OHP	WBR ON CO 6A	LT PCRD O/T ACTED	RELEASED	02:15:00	02:30:00	
5	OHP	CO 29	OLR ACTED	RESET	02:05:00	02:10:00	
6	OHP	CC 28	OLR ACTED	RESET	03:35:00	03:40:00	
7	CHP	CC 54	OLR ACTED	RESET	23:30:00	05:30:00	10 TIMES
8	CHP	CC 51	FEEDING CONV TRIPPED	RESET	23:10:00	05:30:00	15 TIMES
9	CHP	CC 29	OLR ACTED	RESET	22:30:00	22:40:00	
10	CHP	SCR 5 ON CC33	LT DRIVE FAULT	RESET	23:00:00	23:15:00	
11	CHP	SCR 7 ON CC 37	LUFF LIMIT ACTED	RELEASED	23:00:00	23:25:00	
12	CHP	SCR 2 ON CC 40	ZSS INTER LOCK CAGE STUCKED	MADE IT FREE	00:35:00	00:50:00	
13	CHP	SCR 8 ON CC 112	LT O/T ACTED	RELEASED	00:35:00	00:50:00	