



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLr acted	reset	23:40:00	23:50:00	
2	OHP	VF 19	reported red tripped	wrng complaint	03:35:00	03:40:00	
3	OHP	CO 50	OLR acted	reset	05:35:00	05:40:00	
4	CHP	CC 27A	ZSS acted,jamming	informed operation	00:30:00	00:35:00	
5	CHP	CC 31 SCR4	signal missing	LT done and ZSS yard interlock kept in ckt	02:30:00	03:00:00	
6	CHP	CC 31 SCR4	LT not working,pcrd OT acted	OT released	03:47:00	03:55:00	
7	CHP	CC 51	mpd tripped7 times	reset	00:15:00	00:20:00	
8	CHP	CC 114	motor tripped on OLR	reset	04:45:00	04:54:00	
9	WT	OP6	no movement,D5 OLR acted@ coupling	reset	04:40:00	04:55:00	