



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2025

Shift: C

Incharge(s): V Balaji Naik,G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO26	Complaint red found electronic over load acted	Reset done	23:30:00	23:40:00	12.14am to 12.18am :02.15am to 02.20am
2	OHP	stacker on CO20	left luffing not working found drive tripped	Drive reset done then ok	05:00:00	05:10:00	
3	OHP	TT3 on CO21	Chute position indication not coming to OCR found plug loose	Plug inserted properly then ok	00:30:00	00:40:00	
4	CHP	CC131	Motor trip 4 times on over load	Reset done	23:40:00	23:45:00	1.40am to 1.45am:2.40am to 2.45am :3.30am to 3.35am
5	CHP	CC51	MPD trip two times	Reset done	00:42:00	00:47:00	1.48am to 1.52am
6	CHP	CC31 flap gate	Tripped	Reset done	03:40:00	03:50:00	
7	CHP	CC113A	Motor trip 2 times due to over load	Reset done	04:45:00	05:00:00	05.30am to 05.35am
8	CHP	CC111	BRS bypassed as per operational request	Bypassed	22:52:00	22:53:00	
9	CHP	S3 on CC111	Luffing not working found MCCB tripped	Reset done	23:32:00	23:47:00	
10	CHP	SCR7 on CC36	material selection bypassed as per operational request	By pass removed again as per operational request	03:48:00	05:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	SCR4 on CC33	Slew not working found slew area full jamming	Informed to operation after jam clearance ok	03:55:00	04:03:00	
12	CHP	SCR 8 on CC112	Slew not working found 30 degree limit acted	Informed operation	04:07:00	04:20:00	
13	CHP	SCR2 on CC34	LT not working found OT limit acted	Limit released then ok	00:50:00	01:00:00	
14	CHP	CC28	healthy stop found mechanical BRS acting due to belt piece	Informed operation for clearing the belt piece	05:40:00	05:45:00	
15	WT	OP1	No far ward movement found tippler forward limit not opened properly	Limit adjusted and clearance given	02:40:00	02:50:00	