



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 15/09/2025

Area: CHP

Equipment	Job
CC 113 BSS	Two ckts earth fault isolated and made through
CC 113 LDB	RECTIFICATION DONE AND IMPROVED LIGHTING
LC 18,CM 19	Transformer room and panel room cleaning done
CC 222/223	Belt scale systems maintenance was done
CC 31 SCR 4	ZSS and Boom position kept in ckt
JH C 210,211,CC 215 T/E	Pumps auto mode tested , rectified and trial taken
CC 37 HT coupler	Clamp fixed, cable taping done
CC 33,111,R1,S3	PPM was done