



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/05/2025

Area: WT

Equipment	Job
CO 2(Belt)	Bed slots cutting and Alignment done, trail run taken after Mech. clearance, OK
CO 2(Belt)	Gear box changing done by Mech. motor coupling removed and new type coupling fixed
OT 3 series	panel and motor side ppm done
OP 7	panel and motor side ppm done
OP1 and 3	after rake maintenance done