



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 7A	LT not working,LBC not upto reclaiming height	LbC kept at reclaiming height	19:05:00	19:25:00	
2	OHP	CO 8	olr acted	reset	20:00:00	20:10:00	
3	OHP	RSCO 10 A	ZSS probe disturbed,due to material falling	probe adjusted	18:30:00	18:40:00	
4	CHP	CC 51	MPD trips 3 times	reset	16:50:00	17:25:00	
5	CHP	cc 14	ZSS acted ,mechanical problem,bend pulley stucked	informed mechanical	16:40:00	16:50:00	