



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/07/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|---|----------|----------|---------|
| 1 | OHP | CO3B | ZSS complaint found Belt not rotating but pulley rotating due to over load | Informed to operation | 04:35:00 | 04:40:00 | |
| 2 | OHP | CO3B | Over load acted 3 times | Reset done | 04:40:00 | 04:45:00 | |
| 3 | OHP | WOBR on CO6A | Oprator cabin no lights found MCB trip | Made on | 23:00:00 | 23:15:00 | |
| 4 | OHP | WOBR on CO25 | LT not working found PCRD over tension acted | PCRD over tension released then ok | 03:00:00 | 03:20:00 | |
| 5 | CHP | CC114 | BRS bypassed as per operational request | Again in ckt as per operational request | 01:00:00 | 05:50:00 | |
| 6 | CHP | CC53 | motor trip due to over load | Reset done | 03:20:00 | 03:25:00 | |
| 7 | CHP | CC20 | ZSS acted found cage reversed condition | ZSS cage fixed then ok | 22:00:00 | 22:05:00 | |
| 8 | CHP | CC103 | BRS bypassed as per operational requirement | bypass removed as per operational requirement | 02:30:00 | 02:35:00 | |
| 9 | WT | OP6 | Drive 6 over load acted | Reset done | 03:10:00 | 03:20:00 | |