



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	RESET	07:30:00 08:30:00 08:55:00 12:00:00	07:40:00 08:40:00 09:00:00 12:10:00	
2	OHP	CO 26	OLR ACTED	RESET	07:40:00 08:15:00	07:50:00 08:25:00	
3	OHP	BRC ON CO 34	LT O/T ACTED DUE TO GUIDE PROBLEM	RELEASED INFORMED TO MECH	08:30:00	08:40:00	
4	OHP	BRC ON CO 31	B/C OLR ACTED	RESET	09:40:00 10:50:00	09:55:00 11:00:00	
5	OHP	WBR ON CO 26	SLEW DRIVE TRIPPED	RESET	10:40:00	10:50:00	
6	CHP	SCR 6 ON CC38	LT DRIVE TRIPPED	RESET	12:15:00 12:55:00	12:25:00 13:00:00	
7	CHP	CC 31	OLR ACTED	RESET	12:30:00	12:35:00	
8	CHP	SCR 3 ON CC 35	B/C OLR ACTED	RESET	13:20:00	13:30:00	
9	CHP	CC 29	F/G OLR ACTED	RESET	06:30:00 07:50:00	06:35:00 08:00:00	
10	CHP	CC 117	OLR ACTED	RESET	10:40:00	10:50:00	
11	CHP	CC 51	FEEDING MPD TRIPPED	RESET	13:15:00	13:25:00	
12	CHP	CC 51	OLR ACTED	RESET	12:45:00	12:50:00	
13	CHP	CC 54	OLR ACTED	RESET	13:20:00	13:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	AF4	DRIVE TRIPPED DUE TO GROUND FAULT	RESET	12:00:00 12:20:00	12:05:00 13:00:00	MOTOR ME GGERED E VERYTHIN G OK