



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/08/2025

Shift: B

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO33M	Hydraulic pump not working found oil level low showing in operator cabin	Informed to mechanical and operation after filling oil ok	15:30:00	16:00:00	Not an electrical complaint
2	OHP	CO26	olr acted 2 times	Reset done	16:30:00	16:40:00	07.15pm to 07.25pm
3	OHP	VS4a	olr acted	reset done	18:20:00	18:30:00	
4	OHP	CO33m	olr acted	Reset done	19:00:00	19:05:00	
5	OHP	Co11 (carriage)	olr acted	Reset done	20:30:00	20:33:00	
6	OHP	WOBR on CO6a	BW not rotating charge pressure acted	Informed to mechanical	19:20:00	19:30:00	
7	OHP	CO33a	BRS bypassed as per operation request	Again placed in ckt as per operational request	18:00:00	22:05:00	
8	CHP	CC19	Over load acted 2 times	Reset done	14:40:00	14:45:00	03.30 pm to 03.35pm
9	CHP	CC114	olr acted	Reset done	19:10:00	19:15:00	08.30pm to 08.35pm and 09.50pm to 09.55pm
10	CHP	CC54	over load acted 4 times	Reset done	18:05:00	18:30:00	
11	CHP	CC52	Changed from DOL to VFD	trail run taken	14:30:00	16:30:00	