



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/05/2025

Area: OHP

Equipment	Job
CO-6A BRS	electronic brs bypassed due to sensors problem, JOD is in circuit.
om-16,12,10,lc-6,OM-9 ; LOCP-2 CR MCC ;	water levels checking is done. , ENSURED AUTO OPERATION OF PUMPS.