



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TIS on CO 6	TIS FB bypass request from operation	bypassed in IO rack	06:30:00	06:40:00	
2	OHP	CO 26	OLR acted (3 times)	reset done	07:55:00 12:45:00	08:45:00 12:55:00	
3	OHP	CO 11	Carriage drive MPCB tripped	made on	09:45:00	09:55:00	
4	CHP	CC 49	ZSS problem , probe wire got cut	new probe wire connected	09:55:00	10:35:00	
5	CHP	CC 39	BRS not getting reset	PLC input wire loose , connected properly	11:20:00	11:50:00	
6	CHP	CC 201	OLR acted	reset done	11:50:00	12:00:00	
7	CHP	CC 203	OLR acted	reset done	12:40:00	12:50:00	
8	CHP	CC 104, SCR 9	Luff lower limit bypassed as per mechanical request	again kept in circuit	10:30:00	10:45:00	
9	CHP	CC 34 , SCR 2	TUL chute sensor malfunctioning	bypassed in module	12:45:00	13:15:00	to be checked
10	CHP	CC 114	OLR acted	reset done	07:23:00	07:28:00	
11	WT	CO 3 Belt drive	tripped on overload	reset done	08:05:00 09:05:00	08:10:00 09:10:00	
12	WT	Coal pushers	Communication problem	power recycled in cabin	13:25:00	13:35:00	