



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/04/2025

Area: IOSA

Equipment	Job
MISC	RED-OXIDE PAINT APPLIED FOR RUSTED FAN COVERS OF 2 MOTORS
75 KW MOTOR	DEFECTIVE MOTOR COUPLING REMOVED AND SHIFTED TO MIXER BLDG.
SPARE 160KW MOTOR AT OC-11A	MEGGERED AND TRIAL RUN DONE. IR VALUES & CURRENTS RECORDED.
SPARE MOTOR AT OC-9A	MEGGERED AND TRIAL RUN DONE. IR VALUES AND CURRENTS RECORDED.
SPARE 132KW MOTOR	MEGGERED AND TRIAL RUN DONE. IR VALUE AND CURRENTS RECORDED.