



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/02/2026

Area: WT

| Equipment | Job  |
|-----------|--|
| OP 10     | Antenna pipe and Antenna fixed ,Ethernet cable checked and connected       |
| OP 10     | All drives checked and moved in LOCAL                                      |
| OP 10     | Trolly line inspection done  |
| OP 10     | After col no78 Mast is touching to Trolly line,brought to maintenance zone |
| OP 3      | D3 Motor removed for gear box repair job                                   |
| OP 3      | After rake maintenance done  |