



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR1	MOTOR PROTECTION RELAY ACTED	RESET	01:45:00	02:00:00	
2	OHP	CO 111	MPCB TRIPPED	MADE IT ON	04:00:00	04:10:00	
3	CHP	CC 27A T/T TO CC 40	POSITION SENSOR GOT DISTURBED	PROPERLY FIXED THEN OK	23:30:00	23:40:00	
4	CHP	SCR 3 ON CC 33	B/C OLR ACTED	RESET	23:40:00	23:50:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	22:50:00	05:10:00	11 TIMES
6	CHP	CC 131	OLR ACTED	RESET	00:20:00 04:20:00 23:00:00	00:25:00 04:25:00 23:05:00	
7	CHP	CC 117	OLR ACTED	RESET	02:15:00	02:30:00	
8	CHP	CC 54	OLR ACTED	RESET	03:15:00	03:20:00	
9	CHP	CC 52	FEEDING CONV MPD TRIP	RESET	03:40:00	03:45:00	
10	WT	AF6	DRIVE TRIPPED	RESET	22:25:00	22:30:00	
11	WT	OT4	DRIVE2 TRIPPED ON PGF2	RESET	23:20:00	23:30:00	