



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/01/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 26	BC not running. olr acted	reset done	12:40:00	13:00:00	
2	CHP	cc 56	reported c/s not working.	c/s kept wrong position while cleaning chute. kept correct position.	10:30:00	10:50:00	
3	CHP	cc 12	brs not getting reset/sensors alignment distrub	sensors adjusted then ok	11:30:00 11:50:00	11:45:00 12:00:00	
4	CHP	cc 131	tripped on olr 2 times	reset done	07:30:00 10:30:00	07:40:00 10:40:00	
5	CHP	cc 112	tripped on olr2times	reset done	09:50:00	10:00:00	
6	IOSA	tbs on oc 13a	It not taking place/m4 olr acted	reset done	12:20:00	12:45:00	gear box problem