



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	cc 132	motor tripped in olr 6 times	reset	23:45:00	04:10:00	
2	OHP	wobr on co 29	all drive not working,down limit acted,no control supply	luff up done by using bypass and than ok	22:40:00	22:55:00	
3	OHP	TBS on co 22	chute vibrator motor not working,power and control is in off in panel	made it on	22:55:00	23:10:00	
4	OHP	wobr on co 26	slew not working,drive tripped	reset	04:22:00	04:35:00	
5	OHP	co 34	olr acted	reset	04:35:00	04:40:00	
6	OHP	BRC on CO 8A	b/w 2 not running,jamming	informed operation and mechanical	05:00:00	05:15:00	
7	CHP	CC 32	mpd tripped	reset	00:50:00	00:55:00	
8	CHP	cc 39 scr6	slew not working,jamming	informed operation	01:15:00	01:25:00	
9	CHP	cc 40 scr2	b/w not running,	reset pressed in operator cabin	03:00:00	03:10:00	
10	CHP	CC 52	mpd tripped	reset	04:40:00	04:45:00	
11	CHP	CC 117	motor tripped in olr	reset	02:00:00	02:05:00	
12	CHP	cc 131	motor tripped in olr	reset	02:00:00	02:05:00	
13	CHP	cc 51	mpd tripped	reset	04:40:00	04:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT 2 D2	tripped 10 times in PGF1 fault	reset it	23:40:00	00:30:00	it is tripping only in between 100 degree to 130 degree of rotation