



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 14/08/2025

Area: OHP

Equipment	Job
CO 33A, 35A, 37A, 38A, 38B	HOIST PPM DONE
CO 31A, 35A	FEEDER SIDE PPM DONE
CO 8A, DB1, 33A,	MOTOR AND FEEDER PPM DONE
CO 26, CO 19, CO 25, CO 21 , CO 31	YARD FOCUSING AND ROAD FOCUSING LIGHTS GIVEN
VS 4A	Y PHASE DEFECT RECTIFICATION DONE
VS 2A	SPARE MOTOR REMOVING DONE
CC 7, 8 9	BRS INSPECTION DONE
CC 26A	110 KW BURNT MOTOR COUPLING REMOVED AND SENT TO ERS
CC 19	CONTROL MCB REPLACED
CO 15, CO18 , CO14 , CO16	PCS , BRS INSPECTION DONE
CO 3A	ZSS MODULE WELDING DONE
TT4 AND MASTER	RADIO MODEMS AND ANTENNAS INSTALLATION