



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10 A	zss acted,probe alignment problem	probe adjusted than ok	04:05:00	04:15:00	
2	OHP	CO 13	ZSS acted due to loose belt tension	informed operation and mech	23:00:00	23:15:00	
3	OHP	CO 34	OLR acted	reset it done	23:30:00	23:40:00	
4	OHP	BRC on CO 30	b/c not running OLR acted	reset	22:30:00	22:45:00	
5	OHP	CO 26	OLR acted	reset	03:40:00	03:45:00	
6	CHP	CC 33 SCR 4	slew not working,B/w stuck in coal heap	informed operation	22:55:00	23:05:00	
7	CHP	CC 32 scr5	LT not taking place,drive tripped in ol	reset it done	23:45:00	00:00:00	
8	CHP	CC 33 SCR 4	LT not taking place ,OT acted	OT released	04:45:00	05:00:00	
9	CHP	CC 31 R1	luffing not working,b/c and b/w area coal accumulated,full jamming	informed operation	04:15:00	04:30:00	
10	CHP	CC 131	motor tripped in olr	olr reset	03:50:00	03:55:00	
11	WT	CT 2	Inhaul mpcb tripped	made it on	00:25:00	00:30:00	
12	WT	CP 1	NO fwd movement,fwd limit acted	fwd limit released	02:35:00	02:40:00	