



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 26	slew not working,d1 relay not healthy,cabin stop push button loose connection in JB	cable tightened	19:50:00	21:45:00	
2	CHP	CC 51	mpd acted 6 times	reset	15:40:00	15:50:00	
3	CHP	cc 131	olr acted	reset	14:30:00	14:35:00	
4	CHP	CC 40 SCR6	b/c not working olr acted	reset	15:05:00	15:10:00	
5	CHP	CC 43	conveyor olr acted	reset	15:25:00	15:30:00	
6	CHP	cc 31 scr4	B/w not working	operator fault	20:55:00	20:59:00	
7	WT	OP1	no power	power mad eon in LC 2A	16:10:00	16:20:00	