



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/02/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 106 FG	FG POSITION LOGIC IS NOT OK	F/G POSITION BITS REMOVED FROM IO RACK AND SELECTION TAKEN FROM CCR HMI AND TESTED LOGIC.	09:00:00	09:15:00	
2	CHP	SCR 8 ON CC 112	BOOM POSITION	BYPASSED FOR REC PURPOSE	07:10:00	07:30:00	
3	CHP	LC 5	INCOMER 2 TRIPPED	MADE IT ON	11:10:00	11:30:00	
4	CHP	CC 102 T/T	CHUTE SENSOR RETURN PROBLEM	BYPASSED	08:00:00	08:30:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	08:00:00	11:00:00	5 TIMES
6	CHP	RG1	TRIP	RESET	10:10:00	10:30:00	
7	CHP	RG2 F/G	OLR ACTED	RESET	11:00:00	11:10:00	
8	WT	CO 2 CD	OLR ACTED	RESET	13:25:00	13:30:00	