



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/01/2026

Area: WT

Equipment	Job
CP 3 jobs	I/C cable ,panel to Mast(95 *3) made ready
CP 3 jobs	power cable termination done @ panel side for drives
CC 4 level	Lighting complaint, rectified,3 nos L E D bulbs replaced
OP 1,4,5,6 and 8	After rake maintenance done