



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 19/01/2026

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-21	LT not taking place	PCRD chain fallen	17:00:00	17:15:00	Informed to mechanical
2	OHP	CO-85	Reported ZSS acting	Wrong complaint	16:45:00	17:15:00	
3	OHP	WOBR on CO-29	Reported slewing not taking place	Drive tripped.Reset done	21:30:00	21:40:00	
4	CHP	Cc-14	Reported MCB tripping	Checked and found cable rubbing in CJD module.Insulated properly	15:10:00	15:25:00	
5	CHP	CC-24(C/D)	Reported tripped	OLR acted.Reset done	14:20:00	14:30:00	
6	CHP	CC-51	MPD tripped	Reset done(12 times)	14:40:00	21:30:00	
7	CHP	CC-131	Reported tripped	OLR acted.Reset done	15:15:00	15:20:00	
8	CHP	CC-51	Reported tripped	OLR acted.Reset done	21:30:00	21:35:00	
9	CHP	CC-31 SCR-4	Reported Signal missing	LT done and tested okay	17:42:00	17:55:00	
10	CHP	Cc-33 R-1	Luff not working	MPCB tripped.Reset done	18:35:00	18:45:00	
11	CHP	CC-31 SCR-4	Signal missing	ZSS interlock cage problem.Cage and probe changed and tested okay	19:10:00	19:40:00	
12	CHP	CC-213 SCR-9	Luff not taking place	MPCB tripped.Reset done	20:05:00	20:15:00	