



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/12/2025

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------------|-----------------------------------|-----------------------------|----------|----------|----------|
| 1 | OHP | CO 21 | ZSS CAGE PROBLEM | REPLACED | 00:30:00 | 01:00:00 | |
| 2 | OHP | CO 11A ZSS | PROBE DISTANCE ADJUSTED | THEN OK | 00:30:00 | 00:50:00 | |
| 3 | OHP | CO 44 TIS | POWER MPCB TRIP | MADE IT ON | 00:00:00 | 00:15:00 | |
| 4 | OHP | CO 84 | OLR ACTED | RESET | 23:20:00 | 23:30:00 | |
| 5 | CHP | SCR 10 ON CC 105 LT | PCRD CABLE FELL DOWN | WINDING DONE | 00:45:00 | 01:05:00 | |
| 6 | CHP | SCR 4 ON CC 31 | B/C BURNT MOTOR REPLACED | CHECKED AND GIVEN CLEARENCE | 22:00:00 | 23:30:00 | |
| 7 | CHP | CC 51 | FEEDING CONV MPD ACTED | RESET | 23:30:00 | 04:45:00 | 12 TIMES |
| 8 | CHP | CC 54 | OLR ACTED | RESET | 00:45:00 | 02:30:00 | 6 TIMES |
| 9 | CHP | SCR 8 ON CC 112 | PCRD CABLE CAME OUT OF HT COUPLER | INFORMED TO DNW | 05:30:00 | 06:00:00 | |
| 10 | CHP | SCR 3 ON CC 35 | LT DRIVE TRIPPED | RESET | 04:15:00 | 04:25:00 | |
| 11 | CHP | SCR 4 ON CC 31 LUFF | OIL LEVEL LOW | INFORMED TO MECH | 00:25:00 | 00:40:00 | |
| 12 | IOSA | BRC ON OC 15A | CT LIMIT LEVER BROKEN | REPLACED THEN OK | 03:15:00 | 03:30:00 | |