



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/09/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|---|----------------------------------|----------------------------------|-------------------------|
| 1 | OHP | WOBR ON CO-26 | SLEW NOT WORKING CHECKED OLR ACTED | OLR RESET DONE | 07:05:00 | 07:25:00 | |
| 2 | OHP | TW-6 | OLR ACTED | RESET DONE | 07:30:00 | 07:40:00 | |
| 3 | OHP | WOBR ON CO-26 | LT NOT TAKING PLACE CHECKED PCRD CHAIN BROKEN | INFORMED TO MECHANICAL AND PCRD CABLE LOOP GIVEN AND CLEARANCE GIVEN TO OPERATION | 12:20:00 | 12:30:00 | MECHANICAL JOB GOING ON |
| 4 | OHP | BRC ON CO-28 | LT NOT TAKING PLACE PCRD O/T ACTED | RELEASED | 13:20:00 | 13:35:00 | |
| 5 | CHP | CC-28 | OLR ACTED | RESET DONE | 10:30:00 | 10:40:00 | |
| 6 | CHP | CO-54 | OLR ACTED | RESET DONE | 08:25:00 | 08:35:00 | |
| 7 | CHP | CC-51 | FEEDING CONVEYOR OLR ACTED (3TIMES) | RESET DONE | 08:20:00 12:30:00 13:05:00 | 08:30:00 12:40:00 13:20:00 | |
| 8 | CHP | CC-108 | OLR ACTED | RESET DONE | 11:00:00 | 11:05:00 | |
| 9 | CHP | CC-112 SCR-8 | LUFF NOT WORKING DUE TO OIL LOW LEVEL | INFORMED TO MECHANICAL | 10:30:00 | 10:55:00 | |
| 10 | CHP | CC-37 SCR-7 | SLEW NOT WORKING CHECKED AND FOUND SLEW BREAK ALARM ACTED | SPIDER ALARM RESET DONE THAN OK | 12:00:00 | 12:15:00 | |