



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/01/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment                     | Problem   | Action                       | From                 | To                   | Remarks |
|-------|------|-------------------------------|---|------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 12 ZSS                     | PROBE GOT CUT   | REJOINT                      | 07:20:00             | 07:30:00             |         |
| 2     | CHP  | CC 114                        | OLR ACTED   | RESET                        | 07:20:00             | 07:20:00             |         |
| 3     | CHP  | CC 51                         | FEEDING CONV MPD ACTED                                | RESET                        | 11:55:00             | 13:40:00             | 3 TIMES |
| 4     | CHP  | SCR 6 ON<br>CC 39             | LT M2 TRIPPED   | MADE IT ON                   | 12:50:00             | 13:00:00             |         |
| 5     | CHP  | SC R6 ON<br>CC 39 B/C         | OLR ACTED   | RESET                        | 13:30:00             | 13:40:00             |         |
| 6     | CHP  | CC 131<br>HEALTHY<br>STOPPING | AUXILLARY CONTACK BLOCK LOOSE                         | TIGHTENED                    | 11:00:00             | 11:15:00             |         |
| 7     | WT   | OT2                           | D2 TRIPPED ON PGF1                                    | RESET                        | 08:00:00<br>09:30:00 | 08:05:00<br>09:35:00 |         |
| 8     | WT   | OT4                           | CLAMP LIMIT SWITCHES HIGH MISSING DUE TO CORE PROBLEM | SPARE CORE CONNECTED THEN OK | 13:45:00             | 13:55:00             |         |