



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	olr acted	reset	20:30:00	20:40:00	
2	OHP	Co 26	olr acted	reset	20:50:00	20:59:00	
3	CHP	CC 132	olr acted	reset	16:15:00	16:20:00	
4	CHP	CC 51	olr acted	reset	19:20:00	19:25:00	