



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	reset	18:30:00	18:40:00	
2	OHP	CO 33M	OLR acted	reset	15:30:00	15:35:00	
3	OHP	BRC on CO 31	LT not taking place, selector switch in local	put in remote 1450	14:50:00	15:00:00	
4	OHP	WOBR on CO 29	LT not working, control fuse blown	fuse replaced	15:00:00	15:20:00	
5	CHP	CC 125	olr acted	reset	20:20:00	20:30:00	
6	CHP	CC 51	MPD acted 5 times	reset	15:00:00	15:05:00	
7	IOSA	IOSA STREAM	communication problem stream unhealthy	NIU card power recycle done at LC and OM	15:05:00 16:35:00 20:15:00	15:25:00 16:50:00 20:35:00	3 times