



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-21	LT NOT TAKING PLACE DRIVE TRIP	RESET DONE	06:35:00	06:50:00	
2	OHP	TT-2 ON CO-22	POSITION INDICATION MISSING	PROPERLY PLATE PLACED OPPOSITE SENSOR THAN OK	06:40:00	06:45:00	
3	OHP	CO -34	OLR ACTED (3 TIMES))	RESET DONE	09:20:00	09:40:00	
4	OHP	BF-3A	STOPPING ON ZSS PROBE LOOSE	ZSS PROBE PROPERLY FIXED THAN OK	07:10:00	07:20:00	
5	OHP	TT-2 ON CO-22	C/S INDICATION MISSING FOUND TT POWER CABLE JOINT GOT OPENED	JOINT DONE THAN OK	10:05:00	10:55:00	
6	CHP	CC-27A	REPORTED STOPPING ON ZSS FOUND BELT SLIP	INFORMED TO OPERATION	10:10:00	10:20:00	
7	CHP	CC-131	TRIPPED ON OLR (4TIMES)	RESET DONE	07:40:00	13:45:00	
8	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	08:40:00 09:00:00	08:45:00 09:05:00	
9	CHP	CC-51	MPD ACTED (10 TIMES) FEEDING CONVEYOR STOPED	RESET DONE	08:50:00	13:50:00	
10	CHP	CC-34 SCR-2	LT NOT TAKING PLACE FOUND M-2 OLR TRIP	RESET DONE	09:20:00	09:35:00	
11	CHP	CC-40 SCR-2	REPORTED SLEW NOT WORKING FOUND 30 DEGREE LIMIT ACTED	OPERATION REQUEST LIMIT BYPASSED THAN OK	07:00:00	07:20:00	
12	CHP	CC-31 SCR-4	REPORTED ALL DRIVES ARE NOT WORKING	PLC POWER RECYCLED THAN OK	06:45:00	07:25:00	
13	WT	OT-1	DRIVE-2 PGF-1 FAULT TRIP (4TIMES)	RESET DONE	13:00:00	13:05:00	