



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/06/2025

Area: WT

Equipment	Job
CP 2	panel and motor side ppm done
OT 4	Hydraulic pump1 motor ,coupling fixed and motor placed on bed
CC2 and 3 level	Area lighting,100 Amps main isolator( 4 pole ) neutral pole damaged,directed it
CO 4 level	lighting,200W LED replaced
OT 5	Bay lighting problem rectified, TB connectors in LDB replaced
LC 9	Floor cleaning done
OP 1,3 and 5	after rake maintenance done