



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11 CD	MPCB TRIPPED	MADE IT ON	21:10:00	21:20:00	
2	OHP	CO 34	OLR ACTED	RESET	20:00:00 20:20:00	20:05:00 20:25:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	15:30:00	21:45:00	6 TIMES
4	CHP	CC 131 T/T	FESTOON CONTROL CABLE GOT CUT	CABLE JOINT	17:45:00	19:00:00	BYPASSED AND LATER KEPT IN CIRCUIT
5	CHP	SCR 7 ON CC 37	BREAK FAIL ALARM ACTED IN SPIDER	RESET	15:30:00	15:45:00	
6	CHP	SCR 4 ON CC 31	NO AUXILIARY SUPPLY	MADE IT ON	20:00:00	20:10:00	
7	WT	OT1	DRIVE 1 TRIPPED ON PGF1 FAULT	RESET	14:25:00	14:30:00	