



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/07/2025

Shift: C

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO20	Left boom conveyor ZSS acting found probe got cut	Probe cable rejoined and clearance given	03:30:00	03:40:00	
2	OHP	CO29	olr acted	reset done	05:00:00	05:10:00	
3	OHP	BRC on CO33M	BW1 not started found nothing	operator problem	00:10:00	00:20:00	
4	OHP	CO26	olr acted 2 times	reset done	01:35:00	01:40:00	02.00am to 02.10am
5	OHP	CO7	Thermal over load acted	reset done and emergency PB pressed advised to get released to operation dept	05:50:00	05:55:00	
6	OHP	CT2 inhaul	mpcb trips ,due to overload	reset	00:50:00	00:55:00	
7	CHP	CC51	olr tripped and feeding conveyor got stopped	reset done	23:40:00	23:45:00	
8	CHP	Cc54	olr tripped 3 times	reset done	03:35:00	03:40:00	04.45am to 04.50am:05.00am to 05.05am
9	CHP	SCR 3 CC 40	bc not working,signal missing	LT done than OK	01:45:00	02:05:00	
10	CHP	CC52	ZSS cage damaged	on operational request bypassed to avoid delay and spare ZSS cage replaced bypass removed clearance given	22:40:00	23:10:00	
11	CHP	SCR 7 CC 105	BC not running,cjd acted due to jamming	informed operation	01:55:00	02:05:00	
12	CHP	CC 125	OLR acted	reset	03:05:00	03:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/07/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	SCR1 on Cc35	BW not working found wrong complaint 3 times	Operator problem	01:40:00	01:50:00	
14	WT	OC 1A	belt drive trip	reset	03:00:00	03:05:00	
15	IOSA	L and t WOB on OC18A	BC olr tripped	reset done	03:00:00	03:10:00	