



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/09/2025

Area: WT

Equipment	Job
OT 1 and 2	Panels and Encoder JBs blowing and termination checking done
SCO 1A	Field control cable checked ,found earth fault in Belt Way switch,isolated it.
OC1A level	Lighting job done ,50 W LED bulbs 2 nos replaced
OP 3,4 and 6	After rake maintenance done