



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 16	olr acted	reset	06:40:00	06:45:00	
2	OHP	co 29	olr acted	reset	08:45:00	08:55:00	
3	OHP	co 35	olr acted	reset	09:15:00	09:20:00	
4	OHP	BRC on co 8a	LT and CT not working,olr acted	reset	11:00:00	11:20:00	
5	OHP	CO 25	olr acted	reset	11:15:00	11:20:00	
6	OHP	BRC 34	b/w not running,cp probelm	CP acted,informed mech	08:10:00	08:20:00	
7	CHP	CC 38 SCR 3	b/c signal missing	LT done than ok	08:05:00	08:15:00	
8	CHP	CC 104 scr 9	LT not working,OT acted	OT released	09:14:00	09:25:00	
9	CHP	CC 125	olr acted	reset	10:25:00	10:35:00	
10	CHP	CC 31	olr acted	reset	10:10:00	10:15:00	
11	CHP	CC 202	not healthy,cjd acted,jamming	informed operation	12:00:00	12:20:00	cjd bypass removed,kept in ckt
12	CHP	CC 46	healthy not working, OLR FB acted	olr bypass in l/o rack	10:35:00	10:50:00	
13	CHP	cc 54	olr acted,full jamming	reset,informed operation	08:05:00	08:10:00	
14	CHP	CC 113A	OLr acted	reset	12:20:00	12:25:00	
15	WT	CO 3(B)	MCB tripped due to OL acted	reset	07:10:00	07:20:00	
16	WT	sco 1A	olr acted	reset	06:45:00	06:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	WT	OC 1A(B)	olr acted	reset	10:30:00	10:45:00	
18	IOSA	OC 25 A	olr acted	reset	08:30:00	08:45:00	
19	IOSA	OC 7A	stop in zss ,belt snap	informed mech and operation	12:00:00	12:10:00	
20	IOSA	old woblr	LT not taking place,Ot acted	OT released	07:30:00	07:45:00	