



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 23	BRS probelm,sensor problem	sensor adjusted	15:10:00	15:25:00	
2	OHP	CO 19 tbs	LT not stopping ,brake problem	informed mech,mech adjusted brake	18:10:00	18:20:00	
3	OHP	CO 111(b)	mpcb trips due to ol	made it on	15:45:00	15:50:00	
4	OHP	wobr on co 6a	B/c stopping in zss fault,stone stucked in cage	stone removed	16:15:00	16:30:00	
5	OHP	CO 11 (c)	mpcb tripped	made it on	20:55:00	21:05:00	
6	OHP	OP3	pusher no movement,D5 olr acted	olr reset	21:30:00	21:40:00	
7	CHP	CC 38 scr 3	b/c not running,signal missing	plc power recycle	16:10:00	16:30:00	
8	CHP	CC 36 SCR1	luff not working,up limit lever stucked	released	17:20:00	17:30:00	
9	CHP	CC 35 SCR2	LT not taking place,vfd trips in ol	reset	20:50:00	21:00:00	
10	CHP	CC 44	OLr acted	reset	20:00:00	20:05:00	
11	CHP	CC 32 SCR 5	b/c stopping in zss,zss cage stucked due to bearing failure	zss cage replaced	20:10:00	20:30:00	
12	CHP	CC 54	olr acted	reset	16:30:00	16:35:00	2 times
13	CHP	CC 132	pull chord acted, acted by operation worker	reset	18:15:00	18:20:00	
14	WT	OP 9	no rev movement,rev ls acted due to bushes	RLS released	15:40:00	15:50:00	
15	WT	op6	no movement, d3 olr acted	olr reset	17:35:00	17:45:00	