



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/12/2025

Area: CHP

Equipment	Job
CC-116 gallery lighting	lighting improved in slope area
CC-222	Vibration readings noted
Lighting	LC-17 near tower light incoming supply rectification done
Misc	11kw motor overhauling done
LC-6 UPS Supply	UPS-I/C-1 from IMCC-7F-1 changed to PMCC-14-F-D feeder by laying new 6sqmm cable 40m
CC-35,41,47,50,SCR-3	Running inspection done
CC-204 TO CC-212	ppm work done
CC-111,STK-3,CC-104,SCR-9	ppm work done