



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------------------------|--|--|----------------------------------|----------------------------------|--|
| 1 | OHP | RSCO-1A | ZSS problem | cage loose , fixed properly | 12:20:00 | 12:45:00 | |
| 2 | OHP | CO 35 | OLR acted | reset done | 11:35:00 | 11:40:00 | |
| 3 | OHP | CO 26 | OLR acted | reset done | 09:25:00 10:50:00 | 09:35:00 10:55:00 | |
| 4 | OHP | CO 113 | MPCB tripped due to jamming | made on , Em stop stuck , bypassed | 06:35:00 07:50:00 10:35:00 | 06:45:00 08:20:00 10:45:00 | em stop changed and kept in circuit by G shift |
| 5 | OHP | TT 3 on CO 21 | signal missing | bypassed | 07:30:00 | 07:40:00 | kept in circuit after rectification |
| 6 | OHP | BPC 1 | OLR acted | reset done | 08:45:00 | 09:00:00 | |
| 7 | OHP | WOBR on CO 6A and BRC on CO 34 | stopping on charge pressure | no electrical problem , informed to mech and opn | 08:45:00 | 10:00:00 | |
| 8 | CHP | CC 54 | Tripped on overload (6 times) due to deck sheet jamming | reset done | 09:35:00 | 11:25:00 | |
| 9 | CHP | CC 114 | OLR acted | reset done | 07:25:00 | 07:30:00 | |
| 10 | CHP | CC 24 | ZSS probe joint problem | re joint done | 10:30:00 | 10:40:00 | |
| 11 | CHP | CC 50 | ZSS cage problem | cage replaced and zss kept in circuit | 10:00:00 | 10:15:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|------------------------------------|------------|----------------------|----------------------|---------|
| 12 | WT | SCO 1A | Carriage drive tripped on overload | reset done | 07:15:00 09:05:00 | 07:30:00 09:10:00 | |