



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/08/2025

Area: WT

Equipment	Job
OP 10	Top C clamp ,pad and bottom pad replaced
OP 10	D3 ,R-phase connector near drive replaced
MIs	8 nos U clamps of pusher , edges cutting done
OP 3,5,8 and 10	after rake maintenance done