



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/09/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS1A	olr acted	Reset done	20:50:00	21:00:00	
2	OHP	CO26	olr acted	reset done	18:00:00	18:10:00	
3	OHP	CO29	olr acted	Reset done	15:10:00	15:20:00	
4	OHP	CO15	3 times olr	Reset done	17:00:00	17:10:00	
5	OHP	CO58	MCB trip	Made on	17:20:00	17:30:00	
6	OHP	Co16	olr acted	Reset done	19:00:00	19:10:00	
7	OHP	VS1a	over load due to jamming	Reset and made on	20:15:00	20:25:00	
8	OHP	CO56, CO57	PB not released	Get released	15:35:00	15:45:00	
9	OHP	CO26	olr acted	Reset done	15:15:00	15:25:00	
10	CHP	SCR4 on CC31	LT tension limit acted	Reset done	19:05:00	19:25:00	
11	CHP	Cc108	olr acted	Reset done	18:00:00	18:10:00	
12	CHP	CC51	MPD olr tripped 9 times stopped feeding conveyor	Reset done	15:00:00	21:43:00	
13	CHP	CC131	olr acted	Reset done	20:40:00	20:45:00	
14	IOSA	OC13A	Stpped due to material jamming at area	informed	14:50:00	15:30:00	
15	IOSA	WOBR	Bucket wheel chute struck with boulder	Cleared	15:40:00	16:00:00	