



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/11/2025

Area: WT

Equipment	Job
MIS	RMD room near railway building,supply checked,found cable joint open(digging to be done)
OP 7	Panel and Motor side ppm done
OP 2,3 ,7 and CP 1	After rake maintenance done
CP 4	Trolley line inspection done,found no complaints
CT complex	Lighting timer circuit checked found cable joint melted and got open ,rectified it
MIS	Damaged C-clamps collected from pushers ,20 nos for repair